

Endless Water Reuse

2015
WATER REUSE
CALIFORNIA
ANNUAL
CONFERENCE

Millennium Biltmore Hotel
Los Angeles, CA

March 15-17, 2015



The Advent of True Direct Potable Reuse

Brent Alspach, PE
ARCADIS

Acknowledgements

- Co-Author
 - Gilbert Trejo, El Paso Water Utilities (EPWU)
- El Paso Water Utilities:
 - John Balliew
 - Fernie Rico
 - Aide Zamarron
- ARCADIS
 - Caroline Russell
 - Corin Marron
 - Sanaan Villalobos
 - George Maseeh
 - Dan Olson



Background

Water Resources Overview

El Paso Water Utilities (EPWU)		
Service area population		~ 800,000
Estimated demand (2013)		~ 118,000 AF (105 MGD)
Specific consumption	1970s	225 gpcd
	2013	132 gpcd
Water sources		• Groundwater • Desalinated brackish groundwater • Rio Grande river • Reclaimed water
Average annual rainfall		8.7 inches

Water Resources Overview


El Paso Water Utilities (EPWU)		
Service area population		~ 800,000
Estimated demand (2013)		~ 118,000 AF (105 MGD)
Specific consumption	1970s	225 gpcd
	2013	132 gpcd
Water sources		• Groundwater • Desalinated brackish groundwater • Rio Grande river • Reclaimed water
Average annual rainfall		8.7 inches

Conservation has been effective!

Current Drought Conditions

- Reduced river water allocation:
 - Normal: 60,000 AFY
 - 2013: 10,000 AF
 - Received at least average allocation from the Rio Grande only 3 times in the past 17 yrs
 - Reservoir storage is low
- EPWU has instituted several drought support programs


Combined Elephant Butte and Caballo Reservoir Storage



Courtesy: Texas A&M








June 2, 1994

July 8, 2013



Courtesy: NASA




Elephant Butte Reservoir

dam

Rio Grande

2 km




dam

Rio Grande


2 km



2014 Summer Daily Peak




Daily Peak Without River Water



Long History of Reuse


Fred Hervey Water Reclamation Plant

WWTP designed to meet drinking water standards




Long History of Reuse

EPWU has been using reclaimed water treated to drinking water standards for aquifer recharge since 1985.



Long History of Reuse

**Why not utilize
indirect potable reuse?**



Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	NA	4.3	3.8
Turbidity, NTU	NA	3.8	168	1.6
Nitrate, mg/L as N	8 - 88.7	16.4	1.3	NA
Total Phosphorus, mg/L as P	NA	3.1	0.4	NA
Bromide, mg/L	1.3 - 3.2	0.3	0.09	NA

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	NA		
Turbidity, NTU	NA	3.8		
Nitrate, mg/L as N	8 - 88.7	16.4		
Total Phosphorus, mg/L as P	NA	3.1		
Bromide, mg/L	1.3 - 3.2	0.3		

**Additional
injection treatment
required**

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	NA	4.3	3.8
Turbidity, NTU	NA	3.8	168	1.6
Nitrate, mg/L as N	8 - 88.7	16.4	1.3	NA
Total Phosphorus, mg/L as P	NA	3.1	0.4	NA
Bromide, mg/L	1.3 - 3.2	0.3	0.09	NA

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	4.5	4.5	4.5
Turbidity, NTU	NA	3.8	168	1.6
Nitrate, mg/L as N	8 - 88.7	16.4	1.2	NA
Total Phosphorus, mg/L as P	NA	3.1	0.4	NA
Bromide, mg/L	1.3 - 3.2	0.3	0.09	NA

Typical bromide concentrations in conventional supplies:

0.063 mg/L*

* Water Research Foundation (2011)

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	Additional extraction treatment required		791
Hardness, mg/L	NA			279
TOC, mg/L	NA			3.8
Turbidity, NTU	NA			1.6
Nitrate, mg/L as N	8 - 88.7			NA
Total Phosphorus, mg/L as P	NA			NA
Bromide, mg/L	1.3 - 3.2			NA

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	4.1	4.1	3.8
Turbidity, NTU	NA	3.8	168	1.6
Nitrate, mg/L as N	8 - 88.7	16.4	1.3	NA
Total Phosphorus, mg/L as P	NA	3.1	0.4	NA
Bromide, mg/L	1.3 - 3.2	0.3	0.09	NA

Avoid subsurface injection

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	1.3	1.3	3.8
Turbidity, NTU	NA	3.8	168	1.6
Nitrate, mg/L as N	8 - 88.7	16.4	1.3	NA
Total Phosphorus, mg/L as P	NA	3.1	0.4	NA
Bromide, mg/L	1.3 - 3.2	0.3	0.09	NA

✓ **Direct potable reuse**

Source Water Quality Comparison

Parameters	Rio Bosque Shallow Groundwater	Average 2011 Concentrations @...		
		Bustamante WWTP Effluent	Rogers WTP	
			Rio Grande	Shallow Wells
pH	NA	6.9	8.5	7.8
Alkalinity, mg/L as CaCO ₃	NA	97	176	288
TDS, mg/L	722 - 3,087	1,069	580	791
Hardness, mg/L	NA	228	210	279
TOC, mg/L	NA	1.4	1.4	3.8
Turbidity, NTU	NA	3.8	168	1.6
Nitrate, mg/L as N	8 - 88.7	16.4	1.3	NA
Total Phosphorus, mg/L as P	NA	3.1	0.4	NA
Bromide, mg/L	1.3 - 3.2	0.3	0.09	NA

✓ **Direct to distribution!**

Why Pipe-to-Pipe DPR...?

- Close to proximity of Roberto R. Bustamante WWTP and Jonathan Rogers WTP infrastructure
- Cost of re-treating advanced treated water
- Advanced treated water has better quality than raw water blending supplies [Big Spring (TX) model]
- No regulatory roadblocks

**Direct-to-distribution
DPR makes sense.**

Project Status

Project Status

- Feasibility assessment
- Concept development
- Pilot testing
- Preliminary design
- Detailed design
- Construction

Advanced Purified Water Treatment Plant (APWTP)



Project Status

- ✓ Feasibility assessment
- ✓ Concept development
- Pilot testing
- Preliminary design
- Detailed design
- Construction

Advanced Purified Water Treatment Plant (APWTP)



Project Status

✓ Feasibility assessment

✓ Concept development

- Pilot testing
- Preliminary design
- Detailed design
- Construction

Participation By:

- EPWU
- ARCADIS
- NWRI
- Expert Panel
- TCEQ

Project Status

✓ Feasibility assessment

✓ Concept development

- Pilot testing
- Preliminary design
- Detailed design
- Construction

Participation By:

- EPWU
- ARCADIS
- NWRI
- Expert Panel
- TCEQ

Project Status

- ✓ Feasibility assessment
- ✓ Concept development
- Pilot testing
- Preliminary design
- Detailed design
- Construction

Pilot site under construction




Roberto R. Bustamante WWTP Site



Treatment Processes


Treatment Processes

Bustamante WWTP




Treatment Processes

Bustamante WWTP



APWTP




Treatment Processes

Not covered
today

Other key pilot test components:


- Coagulant testing
- On-line monitoring evaluation
- Process control study
- Finished water pipe loop testing

APWTP




Treatment Processes

APWTP



Denitrifying Filters

APWTP



Objective(s)

Convert dissolved NO_3^- to inert N_2

Remove particulate matter

Provide an additional pathogen barrier

Benefit(s)


Enable the use of NF (vs. RO)

Enhance MF/UF pretreatment

Further reduce public health risk

Denitrifying Filters

APWTP



Objective(s)

Convert dissolved NO_3^- to inert N_2

Remove particulate matter
Reduced capital & operating costs

Provide an additional pathogen barrier

Benefit(s)


Enable the use of NF (vs. RO)

Enhance MF/UF pretreatment

Further reduce public health risk

Denitrifying Filters

APWTP



Objective(s)

Convert dissolved NO_3^- to inert N_2

**Beneficial whether or not
credit is awarded**

Remove particulate matter

Provide an additional pathogen barrier

Benefit(s)


Enable the use of NF (vs. RO)

Enhance MF/UF pretreatment

Further reduce public health risk

Ozone

APWTP



Objective(s)

Reduce MF/UF cleaning frequency

Increase MF/UF flux

Extend MF/UF backwash intervals

Reduce concentrations of emerging contaminants


Benefit(s)

Reduce capital &
operating costs
(???)

Provide unquantified (yet) health benefit

Ozone

APWTP



Objective(s)

Reduce MF/UF cleaning frequency

Increase MF/UF flux

Extend MF/UF backwash intervals

Reduce concentrations of emerging contaminants

Benefit(s)


Reduce capital &
operating costs
(???)

**Research is encouraging,
but not conclusive**

Provide unquantified (yet) health benefit

Ozone

APWTP



Objective(s)

Reduce MF/UF cleaning frequency

Increase MF/UF flux

Extend MF/UF backwash intervals

Reduce concentrations of emerging contaminants

Benefit(s)

Reduce capital &


operating costs

**Also improves public /
consumer confidence**

Provide unquantified (yet) health benefit

Ozone

APWTP



Counter Consideration


No downstream biological filtration
to consume assimilable organic carbon
(AOC)

Impact

Increase RO biofouling?

Membrane Filtration

APWTP



Objective(s)

Maximize removal of pathogens

Achieve filtrate turbidity < 0.1 NTU

Provide optimum NF/RO pretreatment

Benefit(s)


Protect public health / achieve compliance

Exceed SWTR requirements

Minimize particulate fouling

Desalination

APWTP



Objective(s)

Reduce dissolved solids concentrations

Achieve all 1^o and 2^o standards in permeate

Benefit(s)

TDS ≤ 900 mg/L


Chloride ≤ 300 mg/L

Sulfate ≤ 300 mg/L

Maintain Texas and USEPA compliance

Desalination

APWTP



Objective(s)

Provide an additional pathogen barrier

Reduce / remove emerging contaminants

Remove DBP precursors (TOC, bromide, etc.)

Remove DBPs (NDMA, bromate, TTHMs, HAAs...)

Benefit(s)

Protect public health


Provide unquantified (yet) health benefit

Minimize DBP formation

Maintain regulatory compliance

Desalination

APWTP



Objective(s)

Provide an additional pathogen barrier

Reduce / remove emerging contaminants

Remove DBP precursors (TOC, bromide, etc.)

Remove DBPs (NDMA, bromate, TTHMs, HAAs...)

Benefit(s)


Protect public health

TCEQ has not awarded
pathogen removal
credit to RO...

Maintain regulatory compliance

Desalination

APWTP



Objective(s)

Provide an additional pathogen barrier

Reduce / remove emerging contaminants

Remove DBP precursors (TOC, bromide, etc.)

Remove DBPs (NDMA, bromate, TTHMs, HAAs...)

Benefit(s)

Protect public health

Provide unquantified (yet) health benefit


**...but public health protection
is independent of credit**

Minimize DBP formation

Maintain regulatory compliance

UV Disinfection / Advanced Oxidation

APWTP



Objective(s)

Achieve 1.2-log reduction of NDMA

Achieve 0.5-log reduction of 1,4-dioxane

Maximize inactivation of pathogens

Reduce emerging contaminants

Benefit(s)

Protect public health


Protect public health

Protect public health / achieve compliance

Provide unquantified (yet) health benefit

Granular Activated Carbon

APWTP



Objective(s)

Quench peroxide

Remove DBPs

Remove emerging contaminants

Provide an additional pathogen barrier

Benefit(s)

Control oxidation


Maintain regulatory compliance

Provide unquantified (yet) health benefit

Protect public health

Chemical Disinfection

APWTP



Objective(s)


Achieve 3.0-log *Giardia* inactivation

Achieve 4.0-log virus inactivation

Benefit(s)


Protect public health /
achieve compliance

Microbial Barriers




Unit Process	Anticipated Log Removal / Inactivation Credits		
	<i>Crypto</i>	<i>Giardia</i>	Viruses
Denitrifying Filters	0	0	0
MF/UF	4	4	0-1
NF/RO	0-2	0-2	0-2
UV AOP	4-6	4-6	4-6
GAC	0	0	0
Cl ₂	0	3	4
Total	8-12	11-15	8-13

Microbial Barriers



Unit Process	Anticipated Log Removal / Inactivation Credits		
	<i>Crypto</i>	<i>Giardia</i>	Viruses
Denitrifying Filters	0	0	0
MF/UF	4	4	0-1
NF/RO	0-2	0-2	0-2
UV AOP	4-6	4-6	4-6
GAC	0	0	0
Cl ₂	0	3	4
Total	8-12	11-15	8-13
Treatment Objective	< 3.0 x 10 ⁻⁵ oocysts/L	< 7.0 x 10 ⁻⁶ cysts/L	< 2.2 x 10 ⁻⁷ MPN/L


Microbial Barriers



Unit Process	Anticipated Log Removal / Inactivation Credits		
	<i>Crypto</i>	<i>Giardia</i>	Viruses
Denitrifying Filters	0	0	0
MF/UF	4	4	0-1
NF/RO	0-2	2	0-2
UV AOP	4-6		4-6
GAC	0	0	0
Cl ₂	0	3	4
Total	8-12	11-15	8-13
Treatment Objective	< 3.0 x 10⁻⁵ oocysts/L	< 7.0 x 10⁻⁶ cysts/L	< 2.2 x 10⁻⁷ MPN/L

**Based on risk of one infection
In 10,000 people per year**

Microbial Barriers



Unit Process	Anticipated Log Removal / Inactivation Credits		
	<i>Crypto</i>	<i>Giardia</i>	Viruses
Denitrifying Filters	0	0	0
MF/UF	4	4	0-1
NF/RO	4-6	4-6	4-6
UV AOP	4-6	4-6	4-6
GAC	0	0	0
Cl_2	0	3	4
Total	8-12	11-15	8-13
Projected Requirement	5	7	8

Anticipated based on Bustamante WWTP secondary effluent concentrations

Next Steps

Next Steps...

Next Steps... For the Project

✓ Feasibility assessment

✓ Concept development

- Pilot testing
- Preliminary design
- Detailed design
- Construction

Next Steps... For the Project

- ✓ Feasibility assessment
- ✓ Concept development
- Pilot testing
- Preliminary design
- Detailed design
- Construction

Nine (9) month pilot test program to begin in April

Next Steps... For the Project

✓ Feasibility assessment

✓ Concept development

- Pilot testing
- Preliminary design
- Detailed design
- Construction

Some elements of design
may be conducted
concurrent with piloting

Next Steps... For the Industry

✓ Feasibility assessment

✓ Concept development

- Pilot testing
- Preliminary design
- Detailed design
- Construction

Some elements of design
may be conducted
concurrent with piloting

Next Steps... For the Industry

Pipe-to-pipe
DPR is coming

**Advanced Purified Water
Treatment Plant
(APWTP)**



Next Steps... For the Industry

...to Texas



Next Steps... For the Industry

...and California?



Next Steps... For the Industry

*“Water should not be judged by its history,
but by its quality.”*

Dr. Louis van Vuuren,
National Institute of Water Research, South Africa (2005)



Questions?

Brent Alspach

ARCADIS

brent.alspach@arcadis-us.com

(760) 602-3828