




Potable Reuse Using Ozone-Biofiltration

September 26, 2018




WaterReuse Webcast Series

© 2018 by the WaterReuse Association

A Few Notes Before We Start...

- Today's webcast will be 90 minutes.
- A PDF of today's presentation can be downloaded when you complete the survey at the conclusion of this webcast.
- If you have questions for the presenters please send a message by typing it into the chat box located on the panel on the left side of your screen.



← Ask a Question

Chat with presenter

Type your question Send

Today's Presenters



Melissa Meeker
Water Innovation Center
Development Director
Gwinnett County
Water Resources



Denise Funk
Director of Research
Gwinnett County
Water Resources



Kati Bell
Director of Water Strategy
Brown and Caldwell



Jennifer Hooper
Senior Environmental Engineer
CDM Smith





Presentation Overview

- Background and Context
- Study Approach
- Research Results
- Cost Comparisons
- Key Findings and Conclusions
- Question and Answer Session



Averages Can Be Misleading



Competition for Water

- ACF Basin goes through three states
- Multiple uses including:
 - Power Generation
 - Drinking Water
 - Navigation
 - Recreation
 - Ecology
 - Fisheries and Agriculture
- 4.2 million people in Atlanta rely on water from the ACF Basin (72% of metro-Atlanta)
- Tri-state water wars ongoing since 1990



Gwinnett County Pipes

Water Distribution System

3,800 miles



Sewer Collection System

3,000 miles



Storm Water System

1,500 miles




Gwinnett County Pipes

Water Distribution System

3,800 miles



Sewer



Gwinnett County DWR Trivia:
End to end all the pipes in Gwinnett County would stretch from Georgia to New Zealand

Storm Water System

500 miles



Gwinnett County Facilities

Water Production

Two Facilities
150 MG per Day
98 MG per Day



Water Reclamation

Three Facilities
60 MG per Day
22 MG per Day
16 MG per Day




Wastewater Pump Stations


220 Pump Stations




Gwinnett County – Challenge of Geography



Facility Locations within Watersheds




Gwinnett County Water Returns and Withdrawals from Lake Lanier




Gwinnett County Indirect Potable Reuse Treatment Trains

F. Wayne Hill Water Resources Process




Shoal Creek Filter Plant Process




Why Study Direct Potable Reuse?

- Diversify water supply and resiliency
- Compare DPR to current IPR system
- Advance the science of Ozone-Biofiltration as an alternative to Reverse Osmosis (RO)-based treatment




WRF Reuse 15-11 Study Approach





Pilot Plant Treatment Train

Lake Lanier
F. Wayne Hill WRC
Advanced Treated
Water



Pilot Plant Facilities



Pilot Plant Controls, Chemicals, and Instruments

HMI for control and data logging



Chemical Tanks

Ozone Panel

Pilot Operational Phases

Phase	Duration	Objectives/Conditions
Baseline	1 month	<ul style="list-style-type: none">• Characterize with 100% Lake Lanier influent• Compare performance with full scale operations• Acclimate biofilters
DPR Testing of Blending Ratios	6 months	<ul style="list-style-type: none">• Test blending ratios• 15, 25, 50, and 100% F. Wayne Hill effluent
Robustness	3 months	<ul style="list-style-type: none">• Autumn lake water quality challenges• Characterize performance over process challenges (e.g. loading rate fluctuation, extended filter run time)




Pilot Analytical Matrix

Parameter	Baseline						
	Influent	Ozone Effluent	Coag/Flocc Effluent	Biofilter Effluent	Biofilter Media	Finished Water	Backwash Water
Biological Indicators	●		●	●	●	●	
Organic Characteristics	●	●	●	●		●	
Trace Chemical Constituents	●					●	
DBPs/DBP-FP	●	●		●		●	
General Water Quality	●	●	●	●		●	●
Inorganic Chemicals						●	
Operational Parameters	●	●	●	●	●	●	●



Quarterly Benchmark Sampling Analytical Matrix



Parameter	Location ID									
	1	2	3	4	5	6	7	8	9	10
Biological Indicators	●		●	●		●	●	●	●	●
Organic Characteristics	●		●	●	●	●	●	●	●	
Trace Chemical Constituents	●				●	●	●	●	●	
DBPs/DBP-FP	●		●	●	●	●	●	●	●	
General Water Quality	●	●	●	●	●	●	●	●	●	
Inorganic Chemicals	●	●	●	●			●	●	●	
Operational Parameters	●	●	●	●	●	●	●	●	●	●

Sampling Events


6 laboratories
+
300 analytical methods
=
Lots of sample bottles





F Wayne Hill WRC Results

Dr. Kati Bell




FWH WRC Discharge Permit Limits

Parameter (Unit)	Permit to Discharge (monthly limits)
Flow (MGD)	60
COD (mg/L)	18
Total Suspended Solids (mg/L)	3
Fecal Coliform (CFU/100 mL)	2 (geometric mean)
Ammonia (mg-N/L)	0.4
Phosphorus, Total (mg/L)	0.08
Turbidity (NTU)	0.5



Turbidity performance




Operational conditions at FWH


Operational Parameter	Sept 6 – 8	Oct 10 – 12	Nov 15 – 16	Dec 12 – 14	Jan 30 – Feb 1	Feb 27 – Mar 1	Mar 27–29	Apr 24–26	May 23–24
Alum (mg/L)	20-35	10	10	10	35	30	10	10	10
Ferric (mg/L)	45-50	20	30	20	40	45	25	25	25
Bio-P upset*	Y	N	N	N	Y	Y	N	N	N
2° effluent P	0.7 to 5	0.5	0.8	0.3	<0.1	<0.1	0.2	0.1	<0.1
NRCY	No nitrate recycle (NRCY) and limited dN, occurring only in 2° clarifiers							NRCY on to bio 2&8 (limited dN in 2° clarifiers)	
Nitrate		~20	~20	~20	~19	~18	~20	14-18	~20 in bios w/o NRCY; bio 2&8 ~9
Other	<ul style="list-style-type: none"> GAC/BAC and UF membrane operations were normal throughout the study Pre-ozone dose was consistently 2.5 mg/L; post-ozone dose was consistently 1.5 mg/L Mean cell retention time (MCRT) changed from 10 to 11 days on 1/25/17 On 5/8/17 pre-ozone dose increased to 3.0 mg/L; and Mg(OH)₂ at plant reduced from 30 to 25 mg/L On 5/8/17 the NRCY turned on to bio 2&8 for bio-P study (plus limited dN in 2° clarifiers); GAC cells were swapped, 17 and 18 taken offline to bring new carbon cells online; additionally, effluent from old and new carbon cells was separated in the effluent channel. 								

Nutrient removal performance

- Turbidity, very low, UF better than GMF



- pH (6.77 to 7.87)
- Nutrients and speciation



Organic carbon

- Surrogates – TOC, DOC, COD
- Not all organic carbon is equal:
 - Phenolic and carboxylic acid derivatives
 - Proteinaceous compounds, amino acids
 - Fulvic and humic acids (or FA-, HA-like)
 - *Trace organic compounds and soluble microbial products are a minor component*
- Additional characterization
 - UV transmittance (UVT) for chromophores
 - Fluorescence EEM for fluorophores





Figure 4-5. Schematic Representation of COD Components for Municipal Wastewater (Melcer, et al., 2003)

99-WWF-3




METHODS FOR WASTEWATER
CHARACTERIZATION IN ACTIVATED
SLUDGE MODELING





TOC performance





Fluorescence Excitation Emission Matrix Spectroscopy

- Organic matter can be electronically excited at particular wavelengths, but only part of the molecule may emit light (fluorescence), in response
- The resulting representation or “fingerprint” localizes fluorescence centers related to groups








fEEM results for FWH WRC





fEEM results for FWH WRC





Microbial removal performance




Microbial quality comparison



TrOCs compounds in FWH WRC




Flame retardants in FWH WRC




Targeted PPCP removal by minor pH adjustments?

- K_{ow} (octanol/water coefficient) is typically used to describe behavior, but does not account for the ionogenicity
- A $\log D_{ow}$ (K_{ow} at pH) approach elucidates mechanisms of removal
 - $\log D_{ow}$ of 1 ($D_{ow} = 10 = 10/1$) is highly hydrophilic
 - > 1 is less hydrophilic, < 1 is more hydrophilic
 - Hydrophobicity is an indicator of “adsorption” characteristics (e.g., to biosolids)
 - Hydrophilicity indicates bioavailability
- The link between nitrification/denitrification and pH is key



Trace Organic Compound Detections	RL	FWH Effluent		Lake Lanier				
		Range	n	n >		Range	n >	
				RL	n		RL	n
1,4-Dioxane (µg/L)	0.07	0.2 - 0.62	9	9	0.07 - 0.07	8	0	
2,4-D (ng/L)	5	5 - 50.2	13	3	5 - 5.4	8	1	
2,4-D (µg/L)	0.1	0.1 - 0.1	10	0	0.1 - 0.1	7	0	
4-Methyl-2-Pentanone (µg/L)	5	5 - 6.4	9	1	5 - 5	8	0	
4-nonylphenol (ng/L)	100	100 - 626	13	10	100 - 700	8	4	
Acesulfame-K (ng/L)	20	20 - 290	13	10	21 - 42	8	8	
Albuterol (ng/L)	5	5 - 32	11	2	5 - 5	8	0	
Atenolol (ng/L)	5	5 - 53	11	1	5 - 5	8	0	
Azithromycin (ng/L)	20	20 - 48	2	1	20 - 20	1	0	
BPA (ng/L)	10	10 - 14	11	1	10 - 30	8	1	
Butalbital (ng/L)	5	5 - 68.8	13	2	5 - 5	8	0	
Butylbenzylphthalate (µg/L)	0.5	0.5 - 0.5	11	0	0.5 - 0.57	7	1	
Caffeine (ng/L)	5	5 - 8.9	11	2	5 - 25	8	3	
Carbadox (ng/L)	5	5 - 28	11	2	5 - 7.5	8	1	
Carbon disulfide (µg/L)	0.5	0.5 - 0.5	9	0	0.5 - 0.5	8	0	
Carisoprodol (ng/L)	5	5 - 50	11	5	5 - 5	8	0	
Chloridazon (ng/L)	5	5 - 12	11	1	5 - 5	8	0	
Cimetidine (ng/L)	5	5 - 360	9	1	5 - 310	7	1	
Cotinine (ng/L)	10	10 - 14	11	1	10 - 10	8	0	
Cyanazine (ng/L)	5	5 - 6.5	11	1	5 - 5	8	0	
DACT (ng/L)	5	5 - 16	11	6	5 - 5	8	0	
DEET (ng/L)	10	10 - 10	11	0	10 - 25	8	2	
Dehydronifedipine (ng/L)	5	5 - 6.1	11	2	5 - 5	8	0	
Di(2-ethylhexyl) phthalate (µg/L)	0.6	0.6 - 0.6	11	0	0.6 - 0.6	7	0	
DIA (ng/L)	5	5 - 16	11	8	5 - 15	8	2	
Dilantin (ng/L)	20	20 - 71	11	1	20 - 480	8	1	
Diltiazem (ng/L)	5	5 - 5	11	0	5 - 10	8	2	
Diuron (ng/L)	5	5 - 5	11	0	5 - 5.4	8	1	
Erythromycin (ng/L)	10	10 - 10	11	0	10 - 24	8	1	
Estrone (LC-MS-MS) (ng/L)	5	5 - 113	13	2	5 - 5.8	8	2	


Trace Organic Compound Detections	RL	FWH Effluent		Lake Lanier				
		Range	n	n >		Range	n >	
				RL	n		RL	n
Ethylparaben (ng/L)	20	20 - 523	13	2	20 - 20	8	0	
Flumequine (ng/L)	10	10 - 10	11	0	10 - 16	8	1	
Ibuprofen (ng/L)	10	10 - 178	13	3	10 - 16	8	1	
Iodide (µg/L)	1	1 - 1.6	4	1	-	0	0	
Iohexal (ng/L)	10	43 - 560	13	13	10 - 43	8	3	
Iopromide (ng/L)	5	5 - 130	13	3	5 - 5	8	0	
m,p-Xylenes (µg/L)	0.5	0.5 - 0.61	9	1	0.5 - 0.5	8	0	
Meprobamate (ng/L)	5	5 - 77	11	7	5 - 5	8	0	
Metazachlor (ng/L)	5	5 - 5	11	0	5 - 5	8	0	
Methylparaben (ng/L)	20	20 - 312	13	3	20 - 20	8	0	
Perfluoro butanoic acid (PFBA) (ng/L)	10	10 - 12	11	2	10 - 10	7	0	
PFOS (ng/L)	5	5 - 7	11	3	5 - 5	7	0	
PFOA (ng/L)	5	8.4 - 16	11	11	5 - 5	7	0	
Perfluoro-1-butanesulfonic acid (ng/L)	5	8.1 - 17	11	11	5 - 5	7	0	
Perfluoro-n-hexanoic acid (ng/L)	5	19 - 49	11	11	5 - 5	7	0	
Perfluoropentanoic acid (ng/L)	5	19 - 50	11	11	5 - 5	7	0	
Primidone (ng/L)	5	5 - 11	11	3	5 - 5	8	0	
Propylparaben (ng/L)	5	5 - 122	13	8	5 - 9.1	8	4	
Quinoline (ng/L)	5	5 - 22	11	2	5 - 14	8	2	
Salicylic Acid (ng/L)	100	100 - 2010	13	5	100 - 100	8	0	
Simazine (ng/L)	5	5 - 20	11	9	7.1 - 24	8	8	
Sucralose (ng/L)	100	100 - 43000	13	11	400 - 1600	8	8	
TCEP (ng/L)	10	95 - 250	11	11	10 - 10	8	0	
TDCPP (ng/L)	100	100 - 180	11	6	100 - 100	8	0	
Testosterone (ng/L)	5	5 - 7.9	11	1	5 - 5	8	0	
Theobromine (ng/L)	10	10 - 10	11	0	10 - 49	8	1	
Theophylline (ng/L)	20	20 - 20	9	0	20 - 25	7	1	
TCCP (ng/L)	100	170 - 670	11	11	100 - 100	8	0	
Xylenes (total) (µg/L)	0.5	0.5 - 0.61	9	1	0.5 - 0.5	8	0	





DPR Pilot Results

Jen Hooper



Pilot Effluent Water Quality

- All blends
 - Biological parameters were **below detection**
 - Total coliform, fecal coliform, *E. Coli*, coliphage (somatic and male-specific/F+- specific coliphage, MS2), *Clostridium perfringens*, *Enterococcus*, *Legionella*, *Cryptosporidium*, and *Giardia*
 - DBPs were low
 - HAA5 (< 22 µg/L)
 - TTHMs (< 13 µg/L)
 - Nitrogenous DBPs (sum of quantifiable detects <9.5 µg/L)
 - NDMA was generally low (average of 3.3 ng/L)
 - Increased to 41 ng/L after ozone, then biofiltration removed NDMA to an average of 14 ng/L
 - Haloquinones (average of 84 ng/L)
- **15% blend** met all primary and secondary MCLs and action levels evaluated

Pilot Effluent Water Quality

15% FWH WRC Blend

- Met ALL Primary and Secondary MCLs evaluated

25% FWH WRC Blend

- **Cyanide:** 0.29 mg/L > 0.2 mg/L MCL
- **NDMA:** 25 ng/L > 10 ng/L CA&MA action levels


50% FWH WRC Blend

- **Nitrate:** 8.20 ± 3.87 mg-N/L, 5/17 samples > 10 mg-N/L MCL
- **Bromate:** 13 μ g/L > 10 μ g/L MCL
- **Di(2-ethylhexyl) phthalate:** 8 μ g/L > 6 μ g/L MCL
- **Color:** 166 CU > 15 CU SMCL (*robustness only*)
- **Manganese:** 0.06 mg/L > 0.05 mg/L SMCL
- **NDMA:** 11 ng/L > 10 ng/L CA&MA action level


100% FWH WRC Blend

- **Nitrate:** 14.3 ± 9.5 mg-N/L > 10 mg-N/L MCL
- **Bromate:** 11 μ g/L > 10 μ g/L MCL
- **Cyanide:** 0.27 mg/L > 0.2 mg/L MCL


Turbidity




TOC




Organic Carbon Compounds




Nitrate




Bromate




Bromide




Nitrosamines





NDMA




Microbial Parameters



Perfluorinated Compounds – FWH Results




Perfluorinated Compounds - DPR Pilot Results




Microbial community analysis


- Collected biofilter samples in April 2017
 - FWH Old GAC
 - FWH New GAC
 - SCFP anthracite
 - DPR pilot anthracite
- Measured the 16S rRNA using Next Generation Sequencing
- Class to family-level information
 - Phylum – Proteobacteria
 - Genus – *Escherichia*
 - Species – *E. coli*
- Operational Taxonomic Units (OTUs) are used *in lieu* of species to evaluate diversity



Classes present at >1% relative abundance




Families present at >1% relative abundance





Comparison of DPR and IPR


Denise Funk



Source Water Quality Summary

Parameter	FWH Advanced Treated Water	Lake Lanier – Shoal Creek Intake
Maximum Temperature (°C)	27.1	24.0
Minimum Temperature (°C)	13.7	11.0
Average Turbidity (NTU)	0.14	0.87
Turbidity Range (NTU)	0.01 to 0.45	0.34 to 6.58
pH Range	6.5 to 7.8	6.0 to 7.3
Average TOC (mg/L)	3.81	1.47
TOC Range (mg/L)	1.8 to 8.0	1.3 to 2.2
Average Nitrate-Nitrite (mg-N/L)	13.9	Very low
Nitrate-Nitrite Range (mg-N/L)	0 to 23.2	<0.2 to 0.87


Temperature




Trace Organic Compounds

CEC Detections	Reporting Limit	DPR Pilot			IPR Pilot		
		Pilot Effluent			Pilot Effluent		
		Range	n	n > RL	Range	n	n > RL
1,4-Dioxane (µg/L)	0.07	0.07 - 0.22	10	6	0.07 - 0.07	4	0
4-nonylphenol - semi quantitative (ng/L)	100	100 - 690	10	3	100 - 100	2	0
Albuterol (ng/L)	5	5 - 160	10	2	5 - 5	2	0
Azithromycin (ng/L)	20	20 - 850	2	1	750 - 750	1	1
Butalbital (ng/L)	5	5 - 7.5	10	1	5 - 5	2	0
Caffeine (ng/L)	5	5 - 11	10	1	5 - 5	2	0
Carbadox (ng/L)	5	5 - 7.7	10	1	5 - 5	2	0
Di(2-ethylhexyl) phthalate (µg/L)	0.6	0.6 - 8	10	4	0.6 - 0.6	3	0
Diltiazem (ng/L)	5	5 - 5.4	10	1	5 - 5	2	0
Erythromycin (ng/L)	10	10 - 10	10	0	10 - 11	2	1
Ethylparaben (ng/L)	20	20 - 27	10	1	20 - 20	2	0
Iohexal (ng/L)	10	10 - 41	10	4	10 - 10	2	0
Meprobamate (ng/L)	5	5 - 11	10	2	5 - 5	2	0
Propylparaben (ng/L)	5	5 - 30	10	2	5 - 7	2	1
Salicylic Acid (ng/L)	100	100 - 150	10	3	100 - 100	2	0
Sucralose (ng/L)	100	240 - 41000	10	10	100 - 100	2	0
TCEP (ng/L)	10	10 - 160	10	9	10 - 10	2	0
Testosterone (ng/L)	5	5 - 7	10	1	5 - 5	2	0
Tris(chloroisopropyl)phosphate (TCPP) (ng/L)	100	100 - 220	10	6	100 - 100	2	0


Ozone Dose Response by Blend




Lake Lanier Temperature Profiles



Comparing Raw Temp and Turbidity during Seasonal Water Quality Challenge



DPR Filter Effluent Performance Exceeds IPR During Seasonal Water Quality Challenge



Filter Headloss Accumulation Rate


Scenario	Anthracite (ft/hr)	GAC (ft/hr)
Before Robustness		
DPR Pilot (50%)	0.03±0.01	0.07±0.01
IPR Pilot	0.04±0.02	0.09±0.01
During Robustness		
DPR Pilot (50%)	0.04±0.01	0.10±0.01
IPR Pilot	0.08±0.03	0.15±0.04

100 hours longer filter run time


35 hours longer filter run time




Cost Comparison



Economic Analysis – Scenario 1



Economic Analysis – Scenario 2



Economic Analysis – Cost Comparison

Cost Element	Scenario 1 Advanced Wastewater Treatment (GMF-UF/Pre-03/BAC/Post-03)	Scenario 2 Advanced Wastewater Treatment (MF/RO/UV-AOP, RO Brine Mechanical Evaporation)	Potable Water Treatment (O3/BAF/Cl2)	Scenario 1 DPR Treatment	Scenario 2 DPR Treatment
Capital Cost, 30-Year Amortized	\$10.8M	\$30.4M	\$7.01M	\$17.8M	\$37.4M
Average Annual O&M Cost	\$3.38M	\$16.7M	\$7.02M	\$10.4M	\$23.7M
Total Cost, \$/MG Treated	\$780	\$2,820	\$680	\$1,460	\$3,500

More than double the cost!!

Key Findings

- DPR as a source water supply provided potable water quality at a 15% blend using two-stage ozone/biofiltration *without* RO
- Advanced treated water from FWH WRC was of equal or higher quality than Lake Lanier for all biological parameters with *no detections* in the pilot finished water
- Of the 300 analytes measured, nitrate, bromate, and cyanide were the primary contaminants that exceeded potable water quality criteria
- DPR had operational benefits during challenging source water supply conditions including lower ozone demand and lower filter headloss accumulation rates
- The two-stage ozone/biofiltration process was less than *half* the cost of full advanced treatment

Acknowledgements

Project Team

- Denise Funk, PE, BCEE (PI)
- Dr. Kati Bell, PE, BCEE (co-PI)
- Jen Hooper, PE (co-PI)
- Dr. Ben Stanford
- Dr. Ching-Hua Huang
- Eddie Machek
- Georgia Tech co-ops and interns
- Morayo Noibi

Project Advisory Committee

- Kelly Comstock
- Dr. Dan Gerrity
- Dr. Chance Lauderdale
- Alex Mofidi

Water Research Foundation

- Justin Mattingly



THE
Water
Research
FOUNDATION



MWH®

now
part of



Stantec



Gwinnett
Water Resources

DM
mith

Georgia
Tech

eurofins

Eaton Analytical

Sensorex

YSI

a xylem brand

Questions?



*Excellence
in Environmental
Engineering & Science™*



WATERUSE Association 2018
Award for Excellence in
Transformational Innovation

