


Hazen

Impacts of Wastewater Treatment Performance on Advanced Water Treatment




WRF Project 4833



**Troy Walker Water Reuse
Practice Leader**

Integrated Water Management...

...acknowledges the entire water cycle as a single, integrated system, in which water in all its forms is recognized as a critical resource




Part of a Comprehensive Project




SOUTHERN NEVADA
WATER AUTHORITY



THE METROPOLITAN WATER DISTRICT
OF SOUTHERN CALIFORNIA



This Project Focuses on Interconnectivity Among Conventional and Advanced Processes



Module A

WRRF Water Quality Impact and Improvements



Wendell Khunjar, Ph.D., PE
Associate Vice President
Director of Wastewater Innovation




Kelly Landry, Ph.D., ENV SP
Scientist




Background

AWT Success Depends on WRRF Performance




Two Typical Approaches to Advanced Wastewater Treatment



RO-Based Treatment

Non-RO-Based Treatment



Module A Research Goals and Objectives

Document how performance at WRRFs can impact AWT process performance

Data Analyses of WRRFs
and AWTs

Concept Evaluation for
Improvements at WRRFs
vs. AWTs

Module A Research Approach

Project Scope

Data Analyses of
WRRFs and AWTs



Concept Evaluation for
Improvements at
WRRFs vs. AWTs

Pairwise
comparison
of dataset

Screening of
relationships


Cause/Effect
Map

Example Approach - Residuals Management for O₃/BAF Configuration




| AWT Parameter | Combination of WRRF parameters that significantly impact AWT ($p < 0.05$) | Mitigation Approach |
|---------------|---|---|
| DOC removal | Influent BOD | Pre-treatment Load EQ |
| | PC removal efficiency | Change # of clarifiers in service Change PS blanket Implement CEPT Load EQ |

Remember! Correlation Does Not Equal Causation



Interface Parameter Concept



Interface Parameter

Process parameters monitored at the interface between mainstream WRRF and AWT

WRRF effluent = AWT influent


Utilities Evaluated

| WRRF Utility Name | WRRF Train | AWT Train |
|-------------------|--------------------------|--------------|
| Utility No. 1 | 1°, 2° Nit | MF/RO/UV AOP |
| Utility No. 2 | 1°, 2° Nit, 3° Filter/UF | O3 /BAC/O3 |
| Utility No. 3 | 1°, 2° Nit/Denit, MBR | BAC/GAC |
| | | |


Utility No. 1 Process Flow Diagram

Interface Parameters = **Secondary Effluent**


Water Resource Reclamation Facility




Advanced Wastewater Treatment Train




Utility No. 1 Summary of Results




Utility No. 1 Summary of Results



Utility No. 1 Summary of Results






Utility No. 1 Summary of Results



Utility No. 1 Summary of Results

Water Resource Reclamation Facility




Utility No. 2

60 MGD Facility


Interface Parameters = **Secondary Clarifier Effluent**

Existing Facility Process Flow Diagram



Utility No. 2 Summary of Results

Water Resource Reclamation Facility




Interface Parameters = Secondary Effluent

| AWT Parameter | Interface Parameter | +/- | R2 |
|---------------|----------------------------------|-----|------|
| Ferric Used | Sec Eff PO ₄ -P, mg/L | + | 0.44 |
| Tot | Sec Eff TP, mg/L | + | 0.43 |


Secondary Effluent
PO₄-P, mg/L
TP, mg/L

Advanced Wastewater Treatment Train




Utility No. 2 Summary of Results

Water Resource Reclamation Facility




Advanced Wastewater Treatment Train

Secondary Effluent
TP, mg/L
TSS, mg/L




| AWT Parameter | Interface Parameter | +/- | R2 |
|---------------|---------------------|-----|-----|
| GAC Effluent | Sec Eff TP, mg/L | + | .36 |
| COD Load | Sec Eff TSS, mg/L | + | .27 |

Utility No. 2 Summary of Results




Utility No. 2 Summary of Results



Utility No. 2 Summary of Results

Water Resource Reclamation Facility




| WRRF Parameter | +/- | R2 |
|---------------------|-----|------|
| Caustic Dosing Rate | - | 0.34 |

Secondary Effluent
TSS, mg/L

Interface Parameters = Secondary Effluent


Advanced Wastewater Treatment Train



Utility No. 3

11.5 MGD Facility


Interface Parameters = **Membrane Permeate**



Utility No. 3 Summary of Results

Water Resource Reclamation Facility


Advanced Wastewater Treatment Train




Interface Parameters = Membrane Permeate

MP TN, mg/L
MP TKN, mg/L
MP TP, mg/L


| AWT Parameter | Interface Parameter | +/- | R2 |
|---------------|---------------------|-----|------|
| Effluent TN | MP TN, mg/L | + | 0.75 |
| Effluent TP | MP TKN, mg/L | + | 0.35 |
| | MP TP, mg/L | + | 0.53 |



Utility No. 3 Summary of Results




Utility No. 3 Summary of Results




Utility No. 3

20 MGD Facility



Interface Parameters = **Ozone Effluent**



Utility No. 4 Summary of Results




Utility No. 4 Summary of Results




Interface Parameters

| AWT Parameter | Interface Parameter | +/- | R2 |
|--------------------|---------------------|-----|------|
| Membrane Integrity | Alkalinity | + | 0.50 |



Secondary Effluent Alkalinity, mg/L



Utility No. 4 Summary of Results




Utility No. 4 Summary of Results




Interface Parameters

| AWT Parameter | Interface Parameter | +/- | R2 |
|---------------|---------------------|-----|------|
| MF TMP | COD | + | 0.32 |


Secondary Effluent
COD, mg/L



Utility No. 4 Summary of Results





Utility No. 4 Summary of Results




Interface Parameters

| AWT Parameter | Interface Parameter | +/- | R2 |
|---------------|---------------------|-----|------|
| MF TMP | Turbidity | + | 0.05 |

Secondary Effluent Turbidity, NTU



Utility No. 4 Summary of Results



Next Steps

1. Performing direct comparison between WRRF and AWT parameters (eliminating interface parameter step)
2. Evaluating and removing multi-collinearity effects between independent variables
 - Multi-collinearity produces less reliable probabilities
 - Statistical inferences from a model with multi-collinearity may be not dependable
3. Performing multi-linear regression analyses to develop predictive models for AWT performance

Thank You!

Troy Walker

Water Reuse Practice Leader | Hazen and Sawyer

1400 E. Southern Avenue, Suite 340, Tempe, AZ 85282

480-436-7959 (main) | 480 340-3270 (cell)

twalker@hazenandsawyer.com

WRRF Recommendations

- Development of MLR analyses may be developed to estimate WRRF effluent quality that impacts downstream AWT performance
- Comparisons across utilities will be performed to identify similarities or if trends are site specific
- Recommendations to improve performance of key WRRF parameters will be developed
 - Monitoring
 - WRRF control/upgrades
 - AWT upgrades/controls

