

Advanced-Treated Recycle Water: How it Can Help with Nutrient Reduction


Sanjay Reddy

Senior Client Services Manager

APRIL 2025




Our Multifaceted Challenge



01




Nutrients




Nutrient removal solutions must build in flexibility




—
Reduced nitrogen loads equates
to more oxygen left in SF Bay



Permit requirements for compliance schedules




Emerging technologies have considerable benefits




02

Recycled Water




Direct potable reuse regulations – treatment process

Multi-barrier treatment train showing diverse treatment mechanisms



Source: May 2017 City of San Diego Pure Water Program Title 22 Engineering Report

MF/RO Facility is a multi-benefit approach to nutrient removal



Sidestream treatment of highly concentrated reject streams



technology demonstration

- **USA PILOT, 0.1 M³/D, 2017**
- **GERMANY PILOT, 1 M³/D, 2019**
- **HUNGARY PILOT, 10 M³/D, 2019**
- **CANADA BENCH-SCALE, 0.1 M³/D, 2019**
- **CANADA PILOT, 1 M³/D, 2019**
- **USA BENCH-SCALE, 0.1 M³/D, 2019**

Piloting of MABR technology with **Anammox** has been successful for high ammonia and TDS streams




BROWN ET AL | 102:10 • JOURNAL AWWA | PEER-REVIEWED | OCTOBER 2010

Biottta treating combination of high-TDS well water and raw wastewater for perchlorate removal.


Conceptually very similar matrix to RO concentrate!

03

Energy Neutrality



Central San's existing solids process



Green house gas emissions

SCOPE 1, 2 & 3 EMISSIONS

Scope 1: Direct Emissions


- Facility emissions (MHFs, Cogen, Boilers...)
- Central San vehicles emissions

Scope 2: Indirect Emissions

- Purchased electricity (treatment plant, pumping stations...)

Scope 3: Indirect Emissions

- 15 categories associated with upstream & downstream activities




Source: https://ghgprotocol.org/sites/default/files/standards/Corporate-Value-Chain-Accounting-Reporting-Standard_041613_2.pdf

Several optimization projects in progress


Final Design of New UV Disinfection System

- Metered flow and self-cleaning UV lamp system
- Better power control and electrical savings of 50-60% (~250 kw)
- Increase wet weather capacity by an additional 40 MGD to 140 MGD



04


Macro Economics



Inflation the silent killer!



Spectrum of collaborative project delivery options



05


Membrane Performance for Refinery Reuse of Non-Nitrified Wastewater

Secondary process operated with low SRT

- Conventional activated sludge, no nitrification
- Save aeration power costs and still meet BOD and TSS limits
- SRT less than 2 days, more free bacteria and less floc
 - » More challenging to settle, "light and fluffy"
 - » Smaller colloidal particles in effluent
 - » Variability in effluent turbidity
- Membrane manufacturers usually want nitrified WW



Pilot system process flow




Coagulants Tested

- Ferric Chloride
- Aluminum Chlorohydrate (ACH)

Evaluated multiple membrane manufacturers with different characteristics

	Membrane	Operation Mode	Type
Nano-stone	Ultra-filtration	Inside-Out	Ceramic
Toray	Ultra-filtration	Outside-In	Polymeric
Dow	Ultra-filtration	Outside-In	Polymeric
Pall	Micro-filtration	Outside-In	Polymeric



Preliminary refinery water quality objectives



Boiler Feed

Cooling Tower Makeup

Parameter	Unit	Preliminary Refinery Specification	Central San Average Final Effluent Water Quality
Ammonia	mg-N/L	<1.0	25
Calcium Hardness	mg/L as CaCO3	130	250
Chromium (total)	mg/L	1.67	0.53
Copper (total)	µg/L	60	6.2
Lead (total)	µg/L	3.7	0.48
Nickel (total)	µg/L	43	4.1
Nitrate	mg-N/L	15	1.8
Silica	mg/L	25	13.1
TDS	mg/L	280	528



Flux step increases

$$\text{Permeability (gfd/psi)} = \frac{\text{Flux (gfd)}}{\text{Transmembrane Pressure (psi)}}$$





Three-week extended runs

$$\text{Permeability} = (\text{gfd/psi}) \frac{\text{Flux (gfd)}}{\text{Transmembrane Pressure (psi)}}$$




Reverse osmosis operation



RO normalized permeate flow

- Permeate flow metric that adjusts for the temperature and osmotic pressure (as a result of TDS) encountered by each stage
- A sudden and exponential decrease in NPF is associated with biological fouling or scaling
- Cleaning trigger at 90% starting NPF
- Stable and consistent performance while operating on both coagulants



Can meet preliminary refinery water quality objectives

- Ammonia was reduced 95-97%
- Bench tested a few methods to reduce ammonia
- Breakpoint chlorination found to be simple and effective method

Parameter	Unit	Preliminary Refinery Specification	Maximum RO Permeate Concentration
Ammonia	mg-N/L	<1.0	1.6
Calcium Hardness	mg/L as CaCO ₃	130	<3.0
Chromium (total)	mg/L	1.67	<0.002
Copper (total)	µg/L	60	<2.0
Lead (total)	µg/L	3.7	<0.5
Nickel (total)	µg/L	43	<5.0
Nitrate	mg-N/L	15	<0.1
Silica	mg/L	25	<0.5
TDS	mg/L	280	17


Ammonia rejection by RO

- Ammonia Removal Across RO was high 95 – 97%.
- Removal was not quite high enough to meet the refinery target(<1.0) consistently.
- The RO operated in a stable fashion in spite of the non-nitrified feed water.
- As anticipated, recovery increases marginally reduced rejection (c. 2%)

Date	NH ₃ Concentration (mg/L as N)		RO NH ₃ Removal (%)	RO Recovery (%)
	Combined RO Feed/UF Filtrate	RO Permeate		
3/2/2022	37	1.1	97.0	75
3/9/2022	39	1.2	96.9	
3/16/2022	36	1.2	96.7	
3/21/2022	35	1.1	96.9	
3/30/2022	48	1.6	96.7	
4/13/2022	43	1.2	97.2	
4/20/2022	32	1.2	96.3	80
5/25/2022	35	1.6	95.4	
6/6/2022	33	1.4	95.8	


We can meet refinery and CA Title 22 non potable reuse objectives

- Refinery limits estimated from their NPDES permit
- Water quality specifications are preliminary, subject to later discussion and all can be met
- Finished water ammonia is an issue that can be solved by breakpoint chlorination



Parameter	Unit	Maximum RO Permeate Concentration ⁽⁸⁾	Preliminary Refinery Recycled Water Quality Specification ⁽¹⁾	Title 22 Regulatory Compliance Limit
Alkalinity	mg/L as CaCO ₃	not tested ⁽⁹⁾	80	-
Ammonia	mg-N/L	1.6	< 1.0	-
Calcium Hardness	mg/L as CaCO ₃	<3.0	130	-
Chloride	mg/L	1.8	170	-
Chromium (total)	mg/L	<0.002	1.17-1.67 ⁽²⁾	-
Copper (total)	µg/L	<2.0	37-60 ⁽³⁾	-
Lead (total)	µg/L	<0.5	3.7 ⁽⁴⁾	-
Nickel (total)	µg/L	<5.0	43 ⁽⁵⁾	-
Nitrate	mg-N/L	<0.1	15	-
Orthophosphate	mg-PO ₄ /L	<0.03 (<0.01 mg/L as P)	3 (0.97 mg/L as P)	-
Silica (as SiO ₂)	mg/L	<0.5	25	-
Total Coliform	MPN/100 mL	not tested ⁽⁹⁾	-	<2.2 <23 (one sample in 7 day period)
TDS	mg/L	17	280	-
TSS	mg/L	<10 ⁽⁶⁾	< 2.0	-
Turbidity	NTU	All UF systems complied prior to RO typically at 0.05 NTU	-	< 0.2 (95% of time in 24-hour period) < 0.5 (at all times)

MF/RO Facility is a multi-benefit approach to nutrient removal



Conclusions

- Advanced recycle water treatment trains can be designed in a way to remove nutrients
- Advanced treated water may not be the cheapest way to remove nitrogen; however, just implementing biological nitrogen removal seems like a missed opportunity
- Advanced treated water can be tacked on later in time but there will efficiency losses